

EMERGENCY LIGHT TESTING RECORD

Emergency lights

Exits signs_____

Building_____

Requirements: Monthly- 30 second functional list

Annual- 90 minute duration test (note: must be followed up with a 30 second functional test the same day or next day)

MONTHLY TESTER-MUST SIGN (30 second functional tests) ANNUAL TEST (90 minute)

[illegible]